



"THESE DRAWINGS ARE THE PROPERTY OF 'QUALTEK ELECTRONICS' AND NOT TO BE REPRODUCED FOR OR COMMUNICATED TO A THIRD PARTY WITHOUT THE EXPRESS WRITTEN PERMISSION OF AN OFFICER OF QUALTEK ELECTRONICS."


MODEL NO:736W-B
Rating:15A125V/250V AC(UL,CSA,VDE,
FIMKO,DEMKO,NEMKO,SEMKO)
APPROVAL File:

UL	APPROVAL
CSA	APPROVAL
VDE	APPROVAL
FIMKO	APPROVAL
DEMKO	APPROVAL
NEMKO	APPROVAL
SEMKO	APPROVAL




PANEL CUT OUT

CIRCUIT BREAKER TRIP TIME VS AMPERES



Model Number	Current Rating	Overload Percentage	Trip Time (in seconds) VS Amperes at+25
736W-B-101	15A	100%	No Trip
		150%	Trip in 1 hour
		200%	3~30
		300%	1~10
		400%	0.4~2.5
		600%	0.2~0.75
		800%	0.10~0.4
		1000%	0.07~0.3



Dim range (mm)		Tolerance +/- (mm)	Qualtek Electronics Corp. PPC DIVISION		
			Part Number: 736W-B-101		
			Description: CIRCUIT BREAKER/SWITCH ILLUMINATED WITH BLACK BODY AND RED ACTUATOR		
0-1	0.15		Drawn/Date S.CHEN 08-02-99	Checked/Date 08-02-99	Approved/Date JJH/08-02-99
1-6	0.20				
6-18	0.30				
18-50	0.50				
50-120	0.70				
120-250	0.90				
250-500	1.20				