



# MXA 008 Matrix-UPS Battery Extender Cable Kit - Installation

## Parts List

Part Number	Description	Quantity
0W616	battery cable extender cable	1
0W0536	new battery communication cable	1
820-0002	cable tie - 3-7/8" long	2

## Installation

1. Unpack and inspect the Matrix-UPS battery extender cable (harness) and the new communication cable. Notify the carrier or dealer immediately if there is damage. If parts are missing, call the Customer Service telephone number located at the end of this instruction sheet. Recycle the packaging or dispose of it properly. **Note:** The following instructions are based on the assumption that the standard battery cable and communication cable have been disconnected from the UPS components.
2. Install the battery extender cable by inserting one end of extender cable into the standard battery cable connector and inserting the other end into the cable receptacle on the Matrix-UPS EU. Refer to figure 1.
3. Using the new battery communication cable provided in the battery extender cable kit, replace the short standard battery communication cable. Refer to *User's Manual* for additional installation instructions.

